



Estimated Water Needs			
Building No.	No. of Employees	Employee Unit Flow (gpd)	Total Flow (gpd)
1	170	35	5,950
2	355	35	12,425
3A	120	35	4,200
3B	100	35	3,500
3C	65	35	2,275
4	230	35	8,050
5A	200	35	7,000
5B	200	35	7,000
6	223	35	7,805
7	300	35	10,500
8	400	35	14,000
9	400	35	14,000
TOTALS	2,763		96,705



LEGEND	
	12 INCH WATER MAIN
	8 INCH WATER MAIN
	WELL SITE ACCESS EASEMENT

This document, and the ideas and designs incorporated herein, as an instrument of professional service, is the property of Ebert Engineering, Inc., and is not to be used in whole or part, for any other project without the written authorization of Ebert Engineering, Inc. This is a copy and not the original drawing. Any liability whatsoever is limited to the original drawing or our last revision to the original. Reproductions of this drawing without an embossed engineer's seal are not valid.

CONCEPTUAL WATER SYSTEM FOR THE RIVER POINTE LOGISTICS CENTER PREPARED FOR VERTEK CONSTRUCTION MANAGEMENT							
Ebert Engineering, Inc.							
Water and Wastewater Engineering							
PO Box 540				Phone (610) 584 6701			
4397 Skippack Pike				Fax (610) 584 6704			
Skippack, PA 19474				E-mail febert@ebertengineering.com			
Drawn By	Project Engr.	Checked By	Scale	Job No.	Date	Drawing No.	
EMK	FEE	FEE	AS NOTED	026-261	03/01/23	1 of 1	